

محطة طاقة كهربائية عن طريق حرق النفايات بحجم

1.5 MW


المواصفات الفنية

NLAP 1.5 MW Incineration Power Plant Technical Specification

Authors:

Samir Mourad, Malak Zoebi, Maysaa Kamareddine

Last update: 27-Nov-16



طاقة الشمال

North Lebanon Alternative Power

www.nlap-lb.com

Name of document:

D:\NLAP\Projects\1.5MW_MobilePowerPlant\TechnicalDocumentation\251116NLAP-
1.5MW_IncinerationPlant_Report2016.docx

Responsible for Document: Samir Mourad

المضمون

1.....	محطة طاقة كهربائية عن طريق حرق النفايات بحجم	
1.....	المواصفات الفنية	
1.....	NLAP 1.5 MW INCINERATION POWER PLANT	
1.....	TECHNICAL SPECIFICATION	
3.....	تمهيد	1
4.....	الاحتياجات	2
5.....	تصميم المنظومة (SYSTEM DESIGN)	3
6.....	التوربين	4
6.....	<i>Steam system parameters for a 2MW Turbine (14 bar, 195°C)</i>	4.1.1
8.....	المكثف (CONDENSER)	5
9.....	COOLING OF CONDENSOR	6
9.....	SEA WATER DESALTING UNIT FOR CONDENSOR COOLING CYCLE	6.1
9.....	COST FOR COOLING (WITH FRESH SEA WATER CYCLE)	6.2
10.....	خزان الماء (WATER TANK)	7
11.....	مدخل النفايات	8
12.....	المحرقة والمبخر	9
13.....	تنقية الدخان	10
14.....	INCINERATION TESTS	10.1
14.....	<i>Incineration without plastic</i>	10.1.1
16.....	معالجة الرماد (AUFBEREITUNG VON ROSTASCHE) بعد حرق النفايات المنزلية	11
16.....	نظرة عامة	11.1
18.....	FLUREC/FLUWA	11.2
19.....	غرفة التحكم	12
20.....	POTENTIAL CUSTOMERS	13
20.....	2 MW FOR MISHMISH/AKKAR	13.1
23.....	SUPPLIER	14
23.....	تصنيع قطع (...CNC)	14.1
23.....	صب	14.2


هذا المشروع يهدف الى تصنيع اول محطة صنع معظم الاجزاء من مؤسسة طاقة الشمال ومن ضمن ذلك التوربين.


REQVIEW-NEEDS: ReqView Business Needs

File Edit View Project Help

Filter

Contents	* ID	Description	As a(n)	Attributes
1 Introduction	NEEDS-2	1 Introduction		Type: Information
1.1 Purpose	NEEDS-46	1.1 Purpose This is a <i>demo document</i> describing business needs for development of ReqView Desktop tool. The document is not complete.		
1.2 Intended Audience and Reading Suggestions	NEEDS-49	1.2 Intended Audience and Reading Suggestions The target audience for this document are new ReqView users evaluating ReqView and learning how to gather and manage requirements in ReqView.		
2 User Roles	NEEDS-1	2 User Roles		
2.1 Requirements Architect				
2.2 Editor				
2.3 Reviewer				
3 User Stories				
3.1 Data Model				





4.1.1 Steam system parameters for a 2MW Turbine (14 bar, 195°C)

- Main
- About
- Preferences
- Glossary
- Resources
- Tutorials
- Properties Calculators:
 - Saturated Properties
 - Steam Properties
- Equipment Calculators:
 - Boiler
 - Heat Loss
 - Flash Tank
 - PRV w/ Desuperheating
 - Header
 - Deaerator
 - Steam Turbine
 - Steam System Modeler

Steam Turbine Calculator [watch tutorial](#) [view guide](#)

Calculates the energy generated or steam outlet conditions for a steam turbine.

Solve for:	
<input type="text" value="Outlet Properties"/>	
Inlet Steam	
Pressure*	<input type="text" value="200"/> psig
Temperature	<input type="text" value="383"/> °F
Turbine Properties	
Selected Turbine Property	<input type="text" value="Power Out"/>
Isentropic Efficiency *	<input type="text" value="30"/> %
Generator Efficiency *	<input type="text" value="50"/> %
Power Out *	<input type="text" value="2000"/> kW
Outlet Steam	
Pressure*	<input type="text" value="30"/> psig
* Required <input type="button" value="Enter"/> <input type="button" value="reset"/>	


Examples: [Mouse Over](#)

Calculation Details and Assumptions below

WARNING:

- Inlet Steam Contains Condensate
- Steam Condensing in Turbine

Inlet Steam		Mass Flow	5,502.0 <i>klb/hr</i>
Pressure	200.0 <i>psig</i>	Sp. Enthalpy	356.8 <i>btu/lbm</i>
Temperature	383.0 <i>°F</i>	Sp. Entropy	0.545 <i>btu/lbm/R</i>
Phase	Liquid	Energy Flow	1,963.2 <i>MMBtu/hr</i>



Isentropic Efficiency	30.0 %
Energy Out	13.6 <i>MMBtu/hr</i>
Generator Efficiency	50.0 %
Power Out	2,000.0 <i>kW</i>

Outlet Steam		Mass Flow	5,502.0 <i>klb/hr</i>
Pressure	30.0 <i>psig</i>	Sp. Enthalpy	354.3 <i>btu/lbm</i>
Temperature	274.0 <i>°F</i>	Sp. Entropy	0.553 <i>btu/lbm/R</i>
Saturated	0.12	Energy Flow	1,949.5 <i>MMBtu/hr</i>

required steam: about 2500 kg / hour.

Calculation details:

Step 1: Determine Inlet Properties

Using the Steam Property Calculator, properties are determined using Inlet Pressure and the selected second parameter (Temperature, Specific Enthalpy, Specific Entropy, or Quality). The Specific Enthalpy is then multiplied by the Mass Flow to get the Energy Flow:

- Pressure = 200.0 psig
- Temperature = 383.0 °F
- [Steam Property Calculator] => Specific Enthalpy = 356.8 btu/lbm
- Inlet Energy Flow = Specific Enthalpy * Mass Flow
[Inlet Energy Flow = 1,963.2 MMBtu/hr = 356.8 btu/lbm * 5,502.0 klb/hr]

Step 2: Calculate Ideal Outlet Properties (Inlet Entropy equals Outlet Entropy)

- Pressure = 30.0 psig
- Specific Entropy = 0.545 btu/lbm/R
- [Steam Property Calculator] => Specific Enthalpy = 348.5 btu/lbm

Step 3: If solve for 'Isentropic Efficiency', Determine Outlet Properties

Using the outlet specific enthalpy, calculate the isentropic efficiency:

- Isentropic Efficiency = (Inlet Specific Enthalpy - Outlet Specific Enthalpy) / (Inlet Specific Enthalpy - IDEAL Outlet Specific Enthalpy)

Step 3: If solve for 'Outlet Properties', Determine Outlet Specific Enthalpy


1. Isentropic Efficiency = (Inlet Specific Enthalpy - Outlet Specific Enthalpy) / (Inlet Specific Enthalpy - IDEAL Outlet Specific Enthalpy)
2. Isentropic Efficiency * (Inlet Specific Enthalpy - IDEAL Outlet Specific Enthalpy) = (Inlet Specific Enthalpy - Outlet Specific Enthalpy)
3. Outlet Specific Enthalpy = Inlet Specific Enthalpy - Isentropic Efficiency * (Inlet Specific Enthalpy - IDEAL Outlet Specific Enthalpy)
[Outlet Specific Enthalpy = 354.3 btu/lbm = 356.8 btu/lbm - 30.00 % * (356.8 btu/lbm - 348.5 btu/lbm)]

Using the outlet specific enthalpy, calculate the outlet properties:

- Pressure = 30.0 psig
- Specific Enthalpy = 354.3 btu/lbm
- [Steam Property Calculator] => Temperature = 274.0 °F

Step 4: Calculate Steam Turbine Energy Out and Generation (Power Out)

- Energy Out = (Inlet Specific Enthalpy - Outlet Specific Enthalpy) * Mass Flow
[Energy Out = 13.6 MMBtu/hr = (356.8 btu/lbm - 354.3 btu/lbm) * 5,502.0 klb/hr]
- Power Out = Energy Out * Generator Efficiency
[Power Out = 2,000.0 kW = 13.6 MMBtu/hr * 50.00 %]




Length: 6 m, Nbs of tubes 530

Heat transfer between steam and water

6 Cooling of Condensator

6.1 Sea water desalting unit for condensor cooling cycle




Schematic of a [multistage flash desalinator](#)


A – steam in, B – seawater in, C – potable water out, D – waste out, E – steam out
 F – heat exchange, G – condensation collection, H – brine heater


6.2 Cost for cooling (with fresh sea water cycle)

• 500 متر بعيد من البحر: 1000 متر انايب

Cooling	Length [m]	#قصر 6 متر	Price per pipe element	Total price
Pipes	1000	167	\$30	\$5.000
		#Pumps	Price per pump	
Pumps		2	\$200	\$400
				Total cooling
				\$5.400







انظر Master Thesis Maysaa Kamareddine, 2016

10.1 Incineration Tests¹

10.1.1 Incineration without plastic



Figure 1:beginning of combustion




Figure 2: filter media after treatment

¹ Master Thesis Maysaa Kamareddine, 2016



Figure 3:chimney during incineration

Calculation of emissions

$$V_2 = V_1 * (P_1/P_2) * (T_2/T_1) * (Z_2/Z_1)$$

Converting to uniform units

$$V_1 = 314.000 \text{ Nm}^3/\text{h}$$

$$P_1 = 1.000 \text{ atm}$$

$$T_1 = 273.150 \text{ }^\circ\text{K}$$

$$T_2 = 323.150 \text{ }^\circ\text{K}$$

$$P_2 = 1.000 \text{ atm}$$

P_1, T_1 normal conditions

P_2, T_2 specification for exhaust

$Z_1=1$ (ideal), $Z_2=1.01$ (at 1 atm): Compressibility Factor

Calculation for V_2

$$V_2 = 314.000 * (1.000/1.000) * (323.150/273.150) * (1.100/1.100)$$

$$V_2 = 375 \text{ m}^3/\text{h}$$



Or mass of filter before treatment =1300 g


mass after treatment =1364

the total mass of particulate =1364-1300=64 g

375 m^3/h correspond to 64 g

Thus $170 \text{ mg} / \text{m}^3 < 200 \text{ mg} / \text{m}^3$ confirm to Lebanese standard (annex D) **positive results**





Schadstoffe (Alwast)	
Parameter	Wertebereich
Arsen	3 bis 15 mg/kg
Blei	1.000 bis 3.500 mg/kg
Cadium	2 bis 20 mg/kg
Chrom ges.	200 bis 1.000 mg/kg
Kupfer	1.000 bis 10.000 mg/kg
Nickel	100 bis 500 mg/kg
Wertstoffe	
Parameter	Verwertbare Anteile
Fe-Metall	8 %
NE-Metall	2 %
VA-Metall	1 %

مثال

Die Metalle sind ferner in die Fraktionen Eisenmetalle (Fe) und Nichteisenmetalle (NE) zu unterteilen.

drei Hauptbestandteile der Rostasche

المكونات الرئيسية الثلاثة للرماد



84% معادن (minerals)

(وما لم تتغيره عملية الحرق مثل بطون ، حجر،

Im Hinblick auf eine spätere verfahrenstechnische Aufbereitung ist Rostasche in drei Hauptbestandteile aufzuteilen. Hierbei können aufgrund der Inhomogenität der Inputmaterialien nur Schwankungsbreiten angegeben werden. Das Bild 2 zeigt die beispielhafte Zusammensetzung aus uns vorliegenden Materialansprachen.

VA-Metall = Rostfreier Stahl (stainless steel)

ارميد، ...)

10% حديد (و الومينيوم، نحاس)

Unter den Metallen sind eisenhaltiger Schrott, Aluminium,)
(Kupfer und Messing vorhanden

5% لم يحرق ولكن قابل للحرق و يعاد الى المحرقة


(مثل خشب، ورق، ثياب، ...)

Inhaltsstoffe von Rostaschen






- mineralische Fraktion 84%
- Deponie, Wegebau
- Fe- und NE-Metalle 11%
- metallurgische Verwertung
- Unverbranntes 5%
- zurück in die MVA


FLUREC/FLUWA 11.2



chemical ash recycling







نحتاج من البلدية مساحة ارض تساوي 500 متر مربع

Installation cost (materials + project management): 2 MW turbine and generator, pipes, pumps, filters exchanger, condenser about 3 million \$

الايجابيات



14.1 تصنيع قطع (...CNC)

Company	Phone number	Description	Address	E-mail web site
CNC LAB	06 412 895 03 476 916	Manufacture 3D design in plastic & open source hardware	Tripoli, Lebanon Bahsas, Behind Haykalieh Hospital, Harba Bld.	www.cnclab.com info@cnclablb.com
Hasan Al Baba	03 828 256	Manufacture and casting	Tripoli, Lebanon Mina, Industry and Commerce street	
HI-Tech fabrication Fawaz Abdel Hadi	06 442 787 70 751 522	Precision mechanical parts manufacturing brass & steel marking heads maker	Tripoli, Lebanon Mahjar suhi P.O. Box 1274	www.hitechfabrication.com info@hitechfabrication.com sirfawaz@yahoo.com
Hannuf mechanical 'Corporation for casting and art construction	06 387 723 03 717 107	Manufacture and casting	Tripoli, Lebanon Al Badawi	
GPS Steel	03 196 225	Uses electric discharge machining process to shape any metal material rapidly by using desired modeled electrodes	Beirut, Lebanon Burj Hammoud	Gps.steel.co@gmail.com
Riyako factory	79 118 779	3D CNC machine, manufacture cupboard for cars	Tripoli, Lebanon Badawi, behind Al Ridani bakery	